



Jal Jeevan Mission

Har Ghar Jal



Har Ghar Jal
Jal Jeevan Mission

District Level Water Analysis Laboratory, U.P Jal Nigam (Rural), Dist. Mirzapur

Office of Executive Engineer, Abhav Khand, U.P Jal Nigam, Nakahara Road, Teliyaganj, Mirzapur. (Test Address only)

Test report

Sample ID: U2183073519594658

User Information

Name: Sunbeam School Narayanpur Mobile: 8317030217

Email: SunbeamSchoolNarayanpur Pin Code:

Full Address: Village- Sherpur, Gram Panchayat- BISHESHERPUR, Block- Narainpur, District- Mirzapur, State- Uttar Pradesh

Sample description

Source of Sample: Summar sebal Village: Sherpur

Gram Panchayat: BISHESHERPUR Block: Narainpur

District: Mirzapur State: Uttar Pradesh

Address: Remarks:

Latitude: Longitude:

Date & time of sample collection Date & time of sample received in lab Date & time of sample analysed Date & time of report generation

22.04.2024 | 02:45:00 PM

22.04.2024 | 02:49:00 PM

23.04.2024 | 03:40:00 PM

24.04.2024 | 11:13:04 AM

Sunbeam School Narayanpur

Authorised Signatory

Test results

Sunbeam School Narayanpur
Principal

Sr. No.	Parameters tested	Unit of measurement	Requirement (acceptable limit) as per BIS 10500	Permissible limit (in absence of alternate source) as per BIS 10500	Test result value	Remarks
1	Calcium (as Ca)*	mg/l	75	200	38.076	
2	Chloride (as Cl)*	mg/l	250	1000	15.000	
3	Fluoride (as F)*	mg/l	1	1.5	0.642	
4	Iron (As Fe)*	mg/l	1	No Relaxation	0.090	
5	Nitrate (as NO3)*	mg/l	45	No Relaxation	4.900	
6	pH*	NA	6.5-8.5	No Relaxation	7.380	
7	Sulphate (as SO4)*	mg/l	200	400	9.660	

Sr. No.	Parameters tested	Unit of measurement	Requirement (acceptable limit) as per BIS 10500	Permissible limit (in absence of alternate source) as per BIS 10500	Test result value	Remarks
8	TDS*	mg/l	500	2000	292.300	
9	Total Alkalinity (as Calcium Carbonate)*	mg/l	200	600	260.000	
10	Total coliform	CFU/ 100 ml	Shall not be detectable in any 100 ml sample	No Relaxation	0.000	
11	Total Hardness (As CaCO ₃)*	mg/l	200	600	255.000	
12	Turbidity*	NTU	1	5	0.910	

Note:

- 1)*indicates parameters that are NABL accredited.
- 2)This test results related to the sample tested above
- 3)The report shall not to be reproduced in full without approval of authority
- 4)This is the end of the report

Authorised signatory
Avinash kumar Singh (Test Lab Incharge)

*****This is an electronically generated report and does not require a signature.*****

Jal Jeevan Mission aims at potable tap water supply to every home


Let's join hands to ensure drinking water is potable. It helps in preventing water borne diseases and improve public health.

Designed & Developed by NIC Copyright. Copy No:JM 2024

Print

Sunbeam School Narayanpui


Authorised Signatory

Sunbeam School Narayanpui

Principal

SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE

No.

Dated : 25/04/2024

It is certified that an inspection team headed by Dr. Jyoti Mishra (MOCH) from NPHC Narayanpur inspected the Sunbeam School Narayanpur, Sherpur Chauraha (Chunar Road) Mirzapur U.P. on 25/04/2024 and found that the Sunbeam School Narayanpur has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 1 year.

Signature with Seal:

Name : Dr. Jyoti Mishra

Designation : MOCH

Name & Address of the Office / Department : NPHC Narayanpur

Jyoti Mishra
25/4/2024
चिकित्साधिकारी
नया प्रा० स्वा० केन्द्र
नारायणपुर, मीरजापूर

To

Sunbeam School

Narayanpur, Sherpur Chauraha (Chunar Road)

Mirzapur, Utter Pradesh

Sunbeam School Narayanpur


Authorised Signatory

Jyoti Mishra
25/4/2024
चिकित्साधिकारी
नया प्रा० स्वा० केन्द्र
नारायणपुर, मीरजापूर

Sunbeam School Narayanpur

Principal